

ANNEXURE C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. RC/S/2

Dated: 28/03/2024

It is certified that an inspection team headed by Dr. M.K. SOWJANYA

(Name of Officers with designation) from PHED

inspected the GREEN FIELD SCHOOL, VAKADA

(Name & Address of the school) on 28/3/2024 (date of inspection) and on the basis of Water

Test Report (Attached) bearing no. SA/LAB/96/2024 dated 22/2/2024 of

..... (PHED Lab) certified that the

GREEN FIELD SCHOOL, VAKADA (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till : 1 YEAR

Signature with Seal : M.K. Sowjanya 28/3/24

Name : Dr. M.K. SOWJANYA

Designation : CAI

Name & Address of the Office / Department : **MEDICAL OFFICER
PRIMARY HEALTH CENT
VELANGI**

To

GREEN FIELD SCHOOL

VAKADA, KARAPA (M)

KAKINADA - 533462
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. RC No. /S/1

Date: 28-03-2024

It is certified that an inspection team headed by Dr. M.K. SOWJANYA
(Name of Officers with designation) from PRIMARY HEALTH CENTER, VELANGI (Name of
Department / Office) inspected the GREEN FIELD SCHOOL, VAKADA
(Name & Address of the school) on 28/3/24 and found that the GREEN FIELD SCHOOL
(Name of school) has safe drinking water facilities for the students and members of staff of the institution
and is maintaining the hygienic sanitation condition in the school building & the campus as per norms
prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till : 1 YEAR

Signature with Seal : M.K. Sowjanya 28/3/24

Name : Dr. M.K. SOWJANYA

Designation : MEDICAL OFFICER
PRIMARY HEALTH CENT
VELANGI

To

GREEN FIELD SCHOOL

VAKADA, KARAPA (M)

KAKINADA - 533462

(Name & Address of the Institution)

Er. BADAM SUNDARA RAO

M.Tech.,(Geo), M.Tech., (Stru), M.B.A., IGBC. A.P., F.I.E.,
P.G.D.C.M. F.I.V. F.I. Struct.E. A.M. ASCE (USA), FRICS, Sr. P.E.

ARCHITECTURAL ENGINEER
CHARTERED ENGINEER
REGISTERED VALUER-GOVT. OF INDIA (1/127)
REGISTERED VALUER-IBBI (1/2019/10732)
CHARTERED STRUCTURAL ENGINEER
COMPETENT PERSON (FACTORIES ACT)
SENIOR PROFESSIONAL ENGINEER
e-mail : badamsundararao@gmail.com, sundar@sundarassociates.com



SUNDAR ASSOCIATES

ARCHITECTURAL ENGINEERS & CONSULTING ENGINEERS

NABL ACCREDITED QUALITY CONTROL LAB
SOIL INVESTIGATION & SOIL TESTING DIVISION
ISO 9001:2015 and ISO/IEC:17025-2017 Certified
27-9-52, PULAVARTI STREET,
KAKINADA - 533 001.

OFF : 0884-2375985, 2362899 (Tele Fax)
Mobile : 98481 60357

SPECIALISTS IN COMPUTERISED STRUCTURAL ANALYSIS & DESIGN

PANEL ENGINEERS FOR NATIONALISED BANKS, SCHEDULED BANKS, CO-OP.SOCIETIES, INSURANCE COMPANIES ETC.,

PAN No. : ABNPB 7233L UDYAM (MSME) REGISTRATION NO.UDYAM-AP-03-0000596 GSTIN : 37ABNPB7233L1ZE

Ref: SA/LAB/96/2024

Date : 22/02/24

CERTIFICATE OF EXAMINATION

Description of Sample	Water Sample For Drinking Purpose
Account	M/S.GREEN FIELD SCHOOL, VAKADA
Job Code	SA/NN/62/2024
Date of Testing	22-02-2024
Sample	Submitted by Party

Analysis Report

S.No.	Parameters	Results	As per IS:10500-2012	
			Desirable Limit in ppm	Permissible Limit in ppm
1.	p ^H	7.88	6.50-8.50	6.50-8.50
2.	Total Dissolved Solids	156	500	2000
3.	Chlorides (as cl, ppm, max)	106	250	1000
4.	Sulphates as SO ₃	65	200	400
5.	Total Hardness (as caco ₃ , ppm, max)	25	200	600
6.	Alkalinity (as ppm, max)	25	200	600
7.	Fluorides (as F, ppm, max)	0	1.0	1.5
8.	Nitrates (as NO ₃ , ppm, max)	0	45	No relaxation
9.	Iron (as Fe, ppm, max)	0	0.30	No relaxation
10.	Turbidity	0	1	5

Result: The given Water sample is fit for Drinking purpose.

Sundar Associates

(Er. Badam Sundara Rao)

WE BUILD FOR YOUR BETTER LIVING

Visit us at www.sundarassociates.com

Er. BADAM SUNDARA RAO
SUNDAR ASSOCIATES
27-9-52, Pulavarthi Street,
KAKINADA-533 001.