

**Government of Andhra Pradesh**  
**A.P. State Disaster Response and Fire Services Department**  
**Annual Periodical Renewal Fire Certificate**

From:  
Regional Fire Officer  
Andhra Pradesh, Vijayawada

To:  
The District Educational Officer,,  
Kakinada, East Godavari District.

**File No: 17397/EG/RFO/2021, Date:15/04/2021**

**Occupancy NoC RC Number: Rc.No. 2756/A2/2014 Dt., 05/07/2014**

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of Green Field School International (Sri Dhanalakshmi Educational Society), represented by Grandhi Narayana Rao, S.No. 246/6, 250/3, 250/4, 250/5, 250/6P, 250/7P, 252/3p, Vakada (V), Karapa Mandal, - Regarding.

- Ref: 1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.  
2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.  
3. This Office NOC for Occupancy Rc No. Rc.No. 2756/A2/2014 Dt., 05/07/2014, Dt.05/07/2014  
4. Renewal NOC For Occupancy Rc.No. 2756/A2/2014 Dt., 05/07/2014, Dt.27/12/2016  
5. Online Application for Renewal NOC of Grandhi Narayana Rao, S.No. 246/6, 250/3, 250/4, 250/5, 250/6P, 250/7P, 252/3p, Vakada (V), Karapa Mandal, - Inspection report called for Regarding.  
6. Online Inspection Report submitted by Officers of this Department on 14-04-2021.

<< 0 >>

The Management of Green Field School International (Sri Dhanalakshmi Educational Society), represented by Grandhi Narayana Rao, S.No. 246/6, 250/3, 250/4, 250/5, 250/6P, 250/7P, 252/3p, Vakada (V), Karapa Mandal, has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.645630/- vide challan No. 41417350252020, , 31283189092019, 21149228132018, Dated 25/03/2021 at CFMS, Kakinada.

Block-I

,Block-III

,Block-II

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate Grandhi Narayana Rao S.No. 246/6, 250/3, 250/4, 250/5, 250/6P, 250/7P, 252/3p, Vakada (V), Karapa Mandal,, subject to the following conditions.

SI	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 15/04/2021 to 14/04/2026.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.

**Recommended:**

1. This Renewal NOC is issued from Fire Safety Point of view only basing on recommendation of the inspection Committee and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time.
2. This Renewal NOC is valid for Five years only and It is the responsibility of the Builder/Owner to apply for renewal of No Objection certificate, duly remitting the user charges as per G.O.Ms.No.169, Home (Prisons & Fire Service) Department. Dt. 19-12-2019. Two months before expire of this No Objection Certificate.
3. The occupier/Owner /Builder/Management concerned of the building premises, shall maintain the Fire Prevention and Fire Safety Measures provided by the building as per Occupancy NOC at all times for good use by the Occupant (or) Members of Fire Services (or) Both in the event of outbreak of Fire.
4. The Renewal NOC issued based on Inspection Committee report.



17397/EG/RF0/2021

Your Sincerely,

*[Signature]*  
Regional Fire Officer  
Andhra Pradesh, Vijayawada

Copy to Grandhi Narayana Rao, Green Field School International (Sri Dhanalakshmi Educational Society), S.No. 246/6, 250/3, 250/4, 250/5, 250/6P, 250/7P, 252/3p, Vakada (V), Karapa Mandal, East Godavari District

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned

*[Signature]*

**CHAIRMAN  
GREEN FIELD SCHOOL  
VAKADA**

*[Signature]*

**PRINCIPAL  
GREEN FIELD SCHOOL  
VAKADA, KAKINADA, A.P**