

Government of Andhra Pradesh**A.P. State Disaster Response and Fire Services Department****Periodical Renewal Fire Certificate**

From:
Regional Fire Officer
Zone-2,Rajahmundry
Andhra Pradesh.

To:
The District Educational Officer,
Kakinada,

File No: 30479/KKN/RFO/2026, Date:16/03/2026

Occupancy NoC RC Number: 2756/A2/2014

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **Green Field School International (Sri Dhanalakshmi Educational Society)**, represented by **Grandhi Narayana Rao, S.no:246/6, 250/3, 250/4, 250/5, 250/6P, 250/7P, 252/3p, Vakada (V), Karapa Mandal** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 2756/A2/2014, Dt.05/07/2014
 4. Renewal NOC For Occupancy 2756/A2/2014, Dt.15/04/2021
 5. Online Application for Renewal NOC of Grandhi Narayana Rao, S.no:246/6, 250/3, 250/4, 250/5, 250/6P, 250/7P, 252/3p, Vakada (V), Karapa Mandal - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 16-03-2026.

-- X --

The Management of Green Field School International (Sri Dhanalakshmi Educational Society), represented by Grandhi Narayana Rao, S.no:246/6, 250/3, 250/4, 250/5, 250/6P, 250/7P, 252/3p, Vakada (V), Karapa Mandal has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.350640/- vide challan No. 91378734072025, Dated 25/02/2026 at CFMS, CFMS.

Block - III ,Block - I ,Block - II

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Grandhi Narayana Rao S.no:246/6, 250/3, 250/4, 250/5, 250/6P, 250/7P, 252/3p, Vakada (V), Karapa Mandal**, subject to the following conditions.

SI	As Builder	As Occupant	As Security Personnel
----	------------	-------------	-----------------------

Handwritten signature and date: 16/3/26

1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 15/04/2026 to 14/04/2031.


5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
91378734072025	2026-02-25	350640

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

The Inspection committee consists of DDRF0-Kakinada and FSI0-Jagannaikpur has inspected the premisses and offered the remarks as Recommended : The management obtained occupancy NOC from fire service department vide Rc.No.2756/A2/2014 Dated: 05/07/2014 and renewed up to 14/04/2026 vide File No. 17397/EG/RF0/2021 Dated :15/04/2021.Now the management remitted Rs.350640.00 vide challan no 91378734072025 date.25/02/2026 and applied for renewal of fire no objection certificate for 05 years sir. The management provided minimum fire fighting equipment in all 03 blocks ,at the time of inspection tested the equipment randomly and found in working condition sir. The management has requested to grant a period of three to six months for the provision of an additional staircase for second(II) block ,management requesting letter enclosed sir.


16/3/26

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షితమైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."



Your Sincerely,

[Handwritten signature]
16/3/26

Regional Fire Officer
Zone-2, Rajahmundry
Andhra Pradesh.

In case of emergency, please call 101 or 0884-2374592 or 9963726902

Copy to Grandhi Narayana Rao, S.no:246/6, 250/3, 250/4, 250/5, 250/6P, 250/7P, 252/3p, Vakada (V),
Karapa Mandal

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned

